

1 **UNITED KINGDOM CONFORMITY ASSESSMENT**
2 **UK TYPE EXAMINATION CERTIFICATE**

3 **Product Intended for use in Potentially Explosive Atmospheres**
4 **UKSI 2016:1107 (as amended by UKSI 2019:696) – Schedule 3A, Part 1**

5 Type Examination Certificate Number: **ExVeritas 21UKEX1123X** Issue: 2
6 Product: CT221, 210-TC, 210-RTD, 220-TC, 220-RTD, Model 210HZ, & Model 220HZ
7 Manufacturer: Daily Thermetrics Corporation
8 Address: 9600 W. Gulf Bank Road
Houston, Texas 77040
USA

9 This product and any acceptable variation thereto is specified in the schedule to this certificate and the documents therein referred to.

10 ExVeritas Limited Approved Body number 2585, in accordance with Regulation 42 of the Equipment and Protective Systems Intended for Use in Potentially Explosive Atmospheres Regulations 2016, UKSI 2016:1107 (as amended by UKSI 2019:696), certifies that this product has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of products intended for use in potentially explosive atmospheres given in Schedule 1 of the Regulations.

11 Compliance with the applicable Essential Health and Safety Requirements has been assured by compliance with:


EN IEC 60079-0: 2018 **EN 60079-11: 2012**

Except in respect of those requirements listed at section 16 of the schedule to this certificate.

12 If the sign "X" is placed after the certificate number, it indicates that the equipment is subject to special conditions for safe use specified in the schedule to this certificate.

13 This TYPE EXAMINATION CERTIFICATE relates only to the design and construction of the specified product. Further requirements of the Regulations apply to the manufacturing process and supply of this product. These are not covered by this certificate.

14 The marking of the equipment shall include the following:

 II 1 G Ex ia IIC T6...T1 Ga

T_{amb} -40°C to +55°C



No. 8613

On behalf of ExVeritas



S Clarke CEng MSc FIET
Managing Director

This certificate may only be reproduced in its entirety and without any change, schedule included.
The status of this certificate can be verified at www.exveritas.com
For help or assistance relating to this certificate, contact info@exveritas.com.
ExVeritas, Units 16-18, Abenbury Way, Wrexham Industrial Estate, Wrexham, United Kingdom LL13 9UZ.
ExVeritas® is a registered trademark, unauthorised use will lead to prosecution.

Schedule

13 Description of Product

The Daily Thermetrics temperature probes are multipoint temperature measuring probes and come in both a Thermocouple and RTD version. These probes are supplied in the following different models; CT221, 210-TC, 210-RTD, 220-TC, 220-RTD, Model 210HZ and Model 220HZ.

Each of the above variants provide a different maximum number of measuring points and come in both a Thermocouple and RTD type. The different models can be supplied in different thermocouple types based on the temperature application. All variants provide the same design characteristics which are relied upon for safety.

The Thermocouple / RTD wires are insulated inside a solid MgO insulation with the positive and negative leads either being welded together at the end to not touch the sheath, for the TC Type, or terminated into the platinum element for the RTD type. The insulated thermocouple wires are housed within a stainless-steel sheath which is welded closed at the end. The extension lead wires are insulated with an armoured cable sheath. Models 210HZ and 220HZ are not insulated from the sheath.

Each probe is to be supplied by a single linear intrinsically safe barrier with the entity parameters detailed in Table 1. Temperature classification is assigned based on the process temperatures in accordance with the Table 2.

Parameter	RTD Value	TC Value
Ui (V)	30	30
Ii (mA)	101	101
Pi (mW)	750	750
Ci (pF/m)	127.5	85.8
Li (μH/m)	1.75	4.05
<i>NOTE: "Ci" and "Li" correspond to the capacitance and inductance per meter for each individual circuit.</i>		

Table 1 – Entity parameters

Temperature class	Process temperature (°C)
T6	≤ 80
T5	≤ 95
T4	≤ 130
T3	≤ 195
T2	≤ 290
T1	≤ 440

Table 2 – Temperature classification

13.1 Details of change

The following changes are introduced in issue 1 of the certificate:

- Include d.c. voltage option in dielectric strength Routine test.
- Addition of more sensor sheath size options.

The following changes are introduced in issue 2 of the certificate:

- Update of manufacturer address and corresponding QAN

14 Descriptive Documents

14.1 Associated Report and Certificate History:

Report Number	Cert Issue Date	Issue	Comment
R3123/A/1	16/03/2022	0	Initial issue of the Prime Certificate
R4479/A/1	06/03/2023	1	Issue of the first variation, section 13.1 details
R5246/A/1	07/18/2024	2	Issue of the fourth variation, section 13.1 details.

14.2 Compliance Drawings:

Title:	Drawing No.:	Rev. Level:	Date:
--------	--------------	-------------	-------

Certificate: **ExVeritas 21UKEX1123X**

Issue **2**

This certificate may only be reproduced in its entirety and without any change, schedule included.
 For help or assistance relating to this certificate, contact info@exveritas.com.
 ExVeritas, Units 16-18, Abenbury Way, Wrexham Industrial Estate, Wrexham, United Kingdom LL13 9UZ.
 ExVeritas® is a registered trademark, unauthorised use will lead to prosecution.

Schedule

*SENSORS SCHEDULE DRAWINGS	DTC-ATEX/IEC-SENSOR	5	05/20/2024
*INSTALLATION, OPERATION AND MAINTENANCE MANUAL	SENSOR IOM-R4	6	May 20, 2024

**Drawings with * are new or updated in this revision*

15 Specific Conditions of Use

15.1 Special Conditions for Safe Use

- Models 210-TC and 220-TC with ground referenced (grounded) devices are not capable of withstanding the 500 Vrms between the measurement circuit and ground. This must be considered during installation, according to IEC 60079-14.
- The installer must confirm (by calculation or measuring) that the process service temperatures do not cause a temperature rise on the equipment in the hazardous area exceeding the values revealed in the adjacent table.

Temperature class	Process temperature (°C)
T6	≤ 80
T5	≤ 95
T4	≤ 130
T3	≤ 195
T2	≤ 290
T1	≤ 440

15.2 Conditions for Use (Routine tests)

- Each completed temperature probe must be subjected to the dielectric strength tests in accordance with IEC 60079-11: 2011 clause 6.3.13 with the test voltage of 500 Vac or 700Vdc (with ≤3% peak-to-peak ripple) applied between intrinsically safe circuits and the frame of the equipment and also between individual intrinsically safe circuits for a minimum of 60 s.

16 Essential Health and Safety Requirements (Regulations Schedule 1)

Essential Health and Safety Requirements are addressed by the standards listed in section 9 and where required the report listed in section 14.1

The manufacturer shall inform ExVeritas of any modifications to the design of the product described by this schedule.